



SINCE 1896

REPORT

Intertek ETL SEMKO

3933 US ROUTE 11 CORTLAND, NEW YORK 13045

Order No. 3116036

Date: February 21, 2007

REPORT NO. 3116036CRT-001

**RENDERED TO:
TTK S.A.S.
7 ALLÉE DES CHÂTAIGNIERS
ZA DU BUISSON DE LA COULDRE
78190 TRAPPES
FRANCE**

STANDARDS USED

NFPA 262, 2007 Edition, Standard Method of Test for Flame Travel and Smoke of Wires and Cables for Use in Air Handling Spaces, approved August 17, 2006.

NFPA 70, 2005 Edition, National Electrical Code (NEC).

The test procedure covered by this standard was originally developed by Underwriters Laboratories Inc. and published as UL 910, *Standard for Safety Test for Flame-Propagation and Smoke-Density Values for Electrical and Optical-Fiber Cables Used in Spaces Transporting Environmental Air*.

TEST

Test for Flame Propagation and Smoke Density Values for Electrical and Optical Fiber Cables Used in Spaces Transporting Environmental Air.

AUTHORIZATION OF TEST

Mr. Stefan Balatchev, representing the client, TTK S.A.S., authorized the test with purchase order no. SB070206/1.

DESCRIPTION OF SAMPLE

The sample was submitted and identified by the client as FG-AC Water/Acids sensing cable.

An independent organization testing for safety, performance, and certification.

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. Measurement uncertainty budgets have been determined for applicable test methods and are available upon request.

INTRODUCTION

This report describes the results of the NFPA 262, Test for Flame Propagation and Smoke Density Values for Electrical and Optical Fiber Cables Used in Spaces Transporting Environmental Air, performed on samples submitted by TTK S.A.S. and previously described.

The specimens were received February 15, 2007 in good condition, prepared, and test evaluations were conducted at Intertek ETL SEMKO, Cortland, New York.

SUMMARY OF TEST METHOD

This test method uses an apparatus as specified in NFPA 262. A specimen holder was used to expose the test specimens; the holder, 11.25-in. (286-mm) wide and 24 feet in length, was filled with one layer of test specimens. The specimens were exposed to approximately $294,000 \pm 7,300$ Btu/hr (86.0 kW) fire, 4.5 ft (1.4 m) long, for a period of 20 minutes, with a draft of 240 ± 5 ft/min (73 m/min) through the chamber. The distance the flame traveled along the specimen and the amount of smoke generated, were reported.

COMPLIANCE REQUIREMENTS

The requirement assessed to the product tested is in accordance with NFPA 70 (NEC), as described by the appropriate type designated for the product.

RESULTS

Results are reported in **APPENDIX A**.

CONCLUSION

The sample submitted by TTK S.A.S., when tested in accordance with NFPA 262 on February 20, 2007, achieved the following results:

Test 1


PEAK FLAME SPREAD 2.0 FT	PEAK OPTICAL DENSITY 0.02	AVERAGE OPTICAL DENSITY 0.01
Requirement: 5 FT.	Requirement: 0.5	Requirement: 0.15

Test 2

PEAK FLAME SPREAD 2.0 FT	PEAK OPTICAL DENSITY 0.03	AVERAGE OPTICAL DENSITY 0.01
Requirement: 5 FT.	Requirement: 0.5	Requirement: 0.15

The sample was judged to be in compliance with the requirements as outlined in NFPA 262, 2007 Edition, Standard Method of Test for Flame Travel and Smoke of Wires and Cables for Use in Air Handling Spaces.

Test Conducted by:



Brian Connor
Technician
Cabling Products Testing Group

Reviewed and Approved by:



James Tanner
Operations Manager
Cabling Products Testing Group

Attachment: **APPENDIX A**